

区域	线路名称	电压等级(kV)	额定电流(A)	额定电流类型	最大历史电流(A)	最大历史电流日期	负载率(%)	线路性质	线路可开放容量(kW)	实际可开放容量(kW)	所属主变		所属母线
											变电站名称/主变名称	可开放容量(MW)	
扬中	10kV.电缆133线	10kV	550	D5000	114.25	2023-08-22	20.77	轻载	4689.39	4689.39	油坊变/镇江.油坊变/2号主变	8.88	II段母线
扬中	10kV.油平131线	10kV	500	D5000	84.28	2023-08-12	16.86	轻载	4602.27	4602.27	油坊变/镇江.油坊变/2号主变	8.88	II段母线
扬中	10kV.油镇132线	10kV	500	D5000	171.42	2023-08-07	34.28	轻载	3093	3093	油坊变/镇江.油坊变/2号主变	8.88	II段母线
扬中	10kV.油西134线	10kV	550	D5000	276.52	2023-07-15	50.28	中载	1878.87	1878.87	油坊变/镇江.油坊变/2号主变	8.88	II段母线
扬中	10kV.油北136线	10kV	550	D5000	177.12	2023-08-12	32.2	轻载	3600.48	3600.48	油坊变/镇江.油坊变/2号主变	8.88	II段母线
扬中	10kV.油园135线	10kV	550	D5000	261.74	2023-08-28	47.59	轻载	2134.86	2134.86	油坊变/镇江.油坊变/2号主变	8.88	II段母线
扬中	10kV.城南156线	10kV	550	D5000	112.05	2023-08-02	20.37	轻载	4727.49	4727.49	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.北郊157线	10kV	550	D5000	192.73	2023-08-12	35.04	轻载	3330.11	3330.11	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.东郊159线	10kV	550	D5000	321.99	2023-07-13	58.54	中载	1091.33	1091.33	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.健康151线	10kV	550	D5000	176.73	2023-08-06	32.13	轻载	3607.23	3607.23	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.南郊154线	10kV	550	D5000	199.68	2023-07-12	36.31	轻载	3209.74	3209.74	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.西郊161线	10kV	550	D5000	180.79	2023-08-06	32.87	轻载	3536.91	3536.91	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.广场163线	10kV	574	D5000	46.77	2023-07-12	8.15	轻载	6149.11	6149.11	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.江南165线	10kV	501	D5000	53.94	2023-08-13	10.77	轻载	5139.88	5139.88	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.中海167线	10kV	480	D5000	21.92	2023-07-12	4.57	轻载	5439.86	5439.86	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.上水169线	10kV	600	D5000	54.44	2023-08-12	9.07	轻载	6331.49	6331.49	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.城北158线	10kV	550	D5000	168.67	2023-08-13	30.67	轻载	3746.83	3746.83	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.水厂I155线	10kV	200	D5000	75.66	2023-09-05	37.83	轻载	1114.36	1114.36	城东变/镇江.城东变/1号主变	18.2	I段母线
扬中	10kV.华鹏166线	10kV	200	D5000	15.48	2023-07-18	7.74	轻载	2156.68	2156.68	新坝变/	0	
扬中	10kV.新宁164线	10kV	200	D5000	84.24	2023-09-02	42.12	轻载	965.76	965.76	新坝变/	0	
扬中	10kV.新北162线	10kV	550	D5000	174.6	2023-08-12	31.75	轻载	3644.12	3644.12	新坝变/	0	
扬中	10kV.新镇161线	10kV	550	D5000	170.28	2023-07-10	30.96	轻载	3718.95	3718.95	新坝变/	0	
扬中	10kV.新南163线	10kV	550	D5000	221.4	2023-08-16	40.25	轻载	2833.55	2833.55	新坝变/	0	
扬中	10kV.胶鞋165线	10kV	550	D5000	180.84	2023-08-16	32.88	轻载	3536.05	3536.05	新坝变/	0	
扬中	10kV.坝储167线	10kV	550	D5000	10.99	2023-07-09	2	轻载	6477.85	6477.85	新坝变/	0	
扬中	10kV.新西169线	10kV	550	D5000	223.68	2023-08-31	40.67	轻载	2794.06	2794.06	新坝变/	0	
扬中	10kV.金陵II1S41线	10kV	574	D5000	48.2	2023-07-31	8.4	轻载	6124.35	6124.35	沙港变/镇江.沙港变/2号主变	17.07	IV段母线
扬中	10kV.上雅1S42线	10kV	600	D5000	94.4	2023-08-11	15.73	轻载	5639.39	5639.39	沙港变/镇江.沙港变/2号主变	17.07	IV段母线
扬中	10kV.环南I1S43线	10kV	600	D5000	118.7	2023-07-12	19.78	轻载	5218.51	5218.51	沙港变/镇江.沙港变/2号主变	17.07	IV段母线
扬中	10kV.中扬1S44线	10kV	600	D5000	80.6	2023-07-12	13.43	轻载	5878.4	5878.4	沙港变/镇江.沙港变/2号主变	17.07	IV段母线

扬中	10kV.世纪 I 1S11线	10kV	600	D5000	74.9	2023-07-12	12.48	轻载	5977.13	5977.13	沙港变/镇江.沙港变/1号主变	19.55	I 段母线
扬中	10kV.沙城1S12线	10kV	550	D5000	150.1	2023-07-12	27.29	轻载	4068.46	4068.46	沙港变/镇江.沙港变/1号主变	19.55	I 段母线
扬中	10kV.沙北1S13线	10kV	550	D5000	244.5	2023-07-12	44.45	轻载	2433.46	2433.46	沙港变/镇江.沙港变/1号主变	19.55	I 段母线
扬中	10kV.迎江 I 1S14线	10kV	574	D5000 INOM	235.6	2023-09-20	41.05	轻载	2878.58	2878.58	沙港变/镇江.沙港变/1号主变	19.55	I 段母线
扬中	10kV.奥体1S32线	10kV	600	D5000	34.8	2023-09-10	5.8	轻载	6671.66	6671.66	沙港变/镇江.沙港变/2号主变	17.07	II 段母线
扬中	10kV.金陵 I 1S16线	10kV	600	D5000	39	2023-08-26	6.5	轻载	6598.92	6598.92	沙港变/镇江.沙港变/1号主变	19.55	I 段母线
扬中	10kV.城镇222线	10kV	400	D5000	178.16	2023-08-12	44.54	轻载	1763.86	1763.86	扬中变/镇江.扬中变/2号主变	20.52	III 段母线
扬中	10kV.前进220线	10kV	550	D5000	155.95	2023-07-12	28.35	轻载	3967.14	3967.14	扬中变/镇江.扬中变/2号主变	20.52	III 段母线
扬中	10kV.长江128线	10kV	481	D5000	85.97	2023-08-15	17.87	轻载	4342.64	4342.64	扬中变/镇江.扬中变/2号主变	20.52	III 段母线
扬中	10kV.工会126线	10kV	550	D5000	269.36	2023-07-12	48.97	轻载	2002.88	2002.88	扬中变/镇江.扬中变/2号主变	20.52	III 段母线
扬中	10kV.工厂124线	10kV	600	D5000	143.47	2023-07-12	23.91	轻载	4789.49	4789.49	扬中变/镇江.扬中变/2号主变	20.52	III 段母线
扬中	10kV.新城123线	10kV	552	D5000	205.71	2023-08-05	37.27	轻载	3129.55	3129.55	扬中变/镇江.扬中变/1号主变	27.32	I 段母线
扬中	10kV.城西125线	10kV	400	D5000	94.12	2023-08-06	23.53	轻载	3219.44	3219.44	扬中变/镇江.扬中变/1号主变	27.32	I 段母线
扬中	10kV.园丁127线	10kV	600	D5000	182.85	2023-07-25	30.48	轻载	4107.43	4107.43	扬中变/镇江.扬中变/1号主变	27.32	I 段母线
扬中	10kV.新扬223线	10kV	400	D5000	105.84	2023-07-12	26.46	轻载	3016.45	3016.45	扬中变/镇江.扬中变/1号主变	27.32	I 段母线
扬中	10kV.花苑 II 182线	10kV	550	D5000	0	2023-09-30	0	轻载	6668.2	6668.2	西来变/镇江.西来变/2号主变	20.51	IV 段母线
扬中	10kV.农具197线	10kV	150	D5000	130.84	2023-09-06	87.23	重载	0	0	西来变/镇江.西来变/1号主变	13.51	I 段母线
扬中	10kV.西旺195线	10kV	550	D5000	29.54	2023-07-12	5.37	轻载	6156.56	6156.56	西来变/镇江.西来变/1号主变	13.51	I 段母线
扬中	10kV.花苑 I 193线	10kV	550	D5000	86.17	2023-08-13	15.67	轻载	5175.73	5175.73	西来变/镇江.西来变/1号主变	13.51	I 段母线
扬中	10kV.西南191线	10kV	550	D5000	0	2023-09-30	0	轻载	6668.2	6668.2	西来变/	0	
扬中	10kV.西来189线	10kV	550	D5000	215.96	2023-07-12	39.27	轻载	2927.77	2927.77	西来变/镇江.西来变/1号主变	13.51	I 段母线
扬中	10kV.西东 II 187线	10kV	550	D5000	56.62	2023-08-06	10.29	轻载	5687.54	5687.54	西来变/镇江.西来变/1号主变	13.51	I 段母线
扬中	10kV.西东 I 185线	10kV	550	D5000	231.79	2023-08-22	42.14	轻载	2653.59	2653.59	西来变/镇江.西来变/1号主变	13.51	I 段母线
扬中	10kV.西北183线	10kV	550	D5000	0	2023-09-30	0	轻载	6668.2	6668.2	西来变/	0	
扬中	10kV.西兴181线	10kV	550	D5000	71.4	2023-09-19	12.98	轻载	5431.55	5431.55	西来变/镇江.西来变/1号主变	13.51	I 段母线
扬中	10kV.金星226线	10kV	550	D5000	89.31	2023-08-05	16.24	轻载	5121.35	5121.35	扬中变/镇江.扬中变/2号主变	20.52	VI 段母线
扬中	10kV.明珠236线	10kV	550	D5000	280.08	2023-08-13	50.92	中载	1817.21	1817.21	扬中变/镇江.扬中变/2号主变	20.52	VI 段母线
扬中	10kV.花城IV 234线	10kV	550	D5000	91.42	2023-08-06	16.62	轻载	5084.8	5084.8	扬中变/镇江.扬中变/2号主变	20.52	VI 段母线
扬中	10kV.新区230线	10kV	550	D5000	231.38	2023-08-17	42.07	轻载	2660.69	2660.69	扬中变/镇江.扬中变/2号主变	20.52	VI 段母线
扬中	10kV.行政228线	10kV	550	D5000	129.58	2023-07-10	23.56	轻载	4423.87	4423.87	扬中变/镇江.扬中变/2号主变	20.52	VI 段母线
扬中	10kV.扬北235线	10kV	550	D5000	0	2023-09-30	0	轻载	6668.2	6668.2	扬中变/镇江.扬中变/1号主变	27.32	V 段母线
扬中	10kV.三茅122线	10kV	550	D5000	325.27	2023-08-12	59.14	中载	1034.52	1034.52	扬中变/镇江.扬中变/1号主变	27.32	V 段母线
扬中	10kV.旺江1C11线	10kV	553	D5000	165.23	2023-07-21	29.88	轻载	3842.78	3842.78	长旺变/镇江.长旺变/1号主变	26.74	I 段母线
扬中	10kV.水泥 I 1C12线	10kV	450	D5000 INOM	266.92	2023-07-28	59.32	中载	832.74	832.74	长旺变/镇江.长旺变/1号主变	26.74	I 段母线

扬中	10kV.旺北1C13线	10kV	553	D5000	119.53	2023-07-26	21.61	轻载	4634.31	4634.31	长旺变/镇江.长旺变/1号主变	26.74	I 段母线
扬中	10kV.旺沙1C14线	10kV	553	D5000	33.39	2023-08-15	6.04	轻载	6126.25	6126.25	长旺变/镇江.长旺变/1号主变	26.74	I 段母线
扬中	10kV.物流 I 1C15线	10kV	553	D5000	156.44	2023-08-25	28.29	轻载	3995.03	3995.03	长旺变/镇江.长旺变/1号主变	26.74	I 段母线
扬中	10kV.旺南1C21线	10kV	553	D5000	130.07	2023-08-04	23.52	轻载	4451.75	4451.75	长旺变/镇江.长旺变/1号主变	26.74	II 段母线
扬中	10kV.化工 I 1C22线	10kV	553	D5000	105.46	2023-07-10	19.07	轻载	4878	4878	长旺变/镇江.长旺变/1号主变	26.74	II 段母线
扬中	10kV.旺长1C23线	10kV	553	D5000	130.07	2023-07-26	23.52	轻载	4451.75	4451.75	长旺变/镇江.长旺变/1号主变	26.74	II 段母线
扬中	10kV.备用1C24线	10kV	553	D5000	0	2023-09-30	0	轻载	6704.57	6704.57	长旺变/	0	
扬中	10kV.备用1C26线	10kV	553	D5000	8.78	2023-08-19	1.59	轻载	6552.5	6552.5	长旺变/镇江.长旺变/1号主变	26.74	II 段母线
扬中	10kV.旺镇1C31线	10kV	553	D5000	232.03	2023-08-17	41.96	轻载	2685.81	2685.81	长旺变/镇江.长旺变/2号主变	22.32	III 段母线
扬中	10kV.水泥 II 1C32线	10kV	450	D5000 INOM	241.69	2023-08-13	53.71	中载	1269.72	1269.72	长旺变/镇江.长旺变/2号主变	22.32	III 段母线
扬中	10kV.旺东1C33线	10kV	553	D5000	124.8	2023-07-15	22.57	轻载	4543.03	4543.03	长旺变/镇江.长旺变/2号主变	22.32	III 段母线
扬中	10kV.旺隆1C34线	10kV	550	D5000	254.88	2023-07-20	46.34	轻载	2253.67	2253.67	长旺变/镇江.长旺变/2号主变	22.32	III 段母线
扬中	10kV.旺园1C35线	10kV	553	D5000 INOM	117.77	2023-09-27	21.3	轻载	4664.79	4664.79	长旺变/镇江.长旺变/2号主变	22.32	III 段母线
扬中	10kV.备用1C36线	10kV	553	D5000	55.54	2023-09-03	10.04	轻载	5742.61	5742.61	长旺变/镇江.长旺变/2号主变	22.32	III 段母线
扬中	10kV.旺港1C41线	10kV	553	D5000	73.82	2023-08-16	13.35	轻载	5426	5426	长旺变/镇江.长旺变/2号主变	22.32	IV 段母线
扬中	10kV.化工 II 1C42线	10kV	553	D5000	84.96	2023-07-24	15.36	轻载	5233.06	5233.06	长旺变/镇江.长旺变/2号主变	22.32	IV 段母线
扬中	10kV.码头1C43线	10kV	553	D5000	0	2023-09-30	0	轻载	6704.57	6704.57	长旺变/	0	
扬中	10kV.长储1C44线	10kV	553	D5000	4.94	2023-07-21	0.89	轻载	6619.01	6619.01	长旺变/镇江.长旺变/2号主变	22.32	IV 段母线
扬中	10kV.物流 II 1C45线	10kV	553	D5000	335.74	2023-08-25	60.71	中载	889.55	889.55	长旺变/镇江.长旺变/2号主变	22.32	IV 段母线
扬中	10kV.中大 II 1S21线	10kV	600	D5000	96.4	2023-07-12	16.07	轻载	5604.75	5604.75	沙港变/镇江.沙港变/2号主变	17.07	III 段母线
扬中	10kV.县中1S22线	10kV	600	D5000	79.4	2023-07-24	13.23	轻载	5899.19	5899.19	沙港变/镇江.沙港变/2号主变	17.07	III 段母线
扬中	10kV.迎江 II 1S23线	10kV	574	D5000	11.4	2023-07-24	1.99	轻载	6761.72	6761.72	沙港变/镇江.沙港变/2号主变	17.07	III 段母线
扬中	10kV.沙东1S24线	10kV	600	D5000	190.4	2023-07-13	31.73	轻载	3976.67	3976.67	沙港变/镇江.沙港变/2号主变	17.07	III 段母线
扬中	10kV.沙联1S25线	10kV	574	D5000	0	2023-09-30	0	轻载	6959.17	6959.17	沙港变/	0	
扬中	10kV.世纪 II 1S45线	10kV	600	D5000	2	2023-09-30	0.33	轻载	7239.76	7239.76	沙港变/镇江.沙港变/2号主变	17.07	IV 段母线
扬中	10kV.中大 I 1S33线	10kV	574	D5000	207.6	2023-07-12	36.17	轻载	3363.54	3363.54	沙港变/镇江.沙港变/2号主变	17.07	II 段母线
扬中	10kV.环南 II 1S31线	10kV	600	D5000	107.7	2023-07-25	17.95	轻载	5409.03	5409.03	沙港变/镇江.沙港变/2号主变	17.07	II 段母线
扬中	10kV.华庭1S34线	10kV	600	D5000	162.8	2023-08-13	27.13	轻载	4454.7	4454.7	沙港变/镇江.沙港变/2号主变	17.07	II 段母线
扬中	10kV.仓能1C11线	10kV	550	D5000	0.07	2023-09-16	0.01	轻载	6666.98	6666.98	仓储变/	0	
扬中	10kV.红专1C12线	10kV	550	D5000	145.86	2023-08-12	26.52	轻载	4141.9	4141.9	仓储变/镇江.仓储变/1号主变	20.53	I 段母线
扬中	10kV.仓纜1C13线	10kV	550	D5000	87.45	2023-08-07	15.9	轻载	5153.56	5153.56	仓储变/镇江.仓储变/1号主变	20.53	I 段母线
扬中	10kV.仓西 I 1C14线	10kV	550	D5000	327.25	2023-09-19	59.5	中载	1000.23	1000.23	仓储变/镇江.仓储变/1号主变	20.53	I 段母线
扬中	10kV.园博 I 1C15线	10kV	550	D5000	35.33	2023-09-19	6.42	轻载	6056.28	6056.28	仓储变/镇江.仓储变/1号主变	20.53	I 段母线
扬中	10kV.仓旺1C16线	10kV	550	D5000	0	2023-09-30	0	轻载	6668.2	6668.2	仓储变/	0	

扬中	10kV.仓江1C21线	10kV	550	D5000	209.2	2023-07-14	38.04	轻载	3044.85	3044.85	仓储变/镇江.仓储变/1号主变	20.53	II段母线
扬中	10kV.仓东1C22线	10kV	550	D5000	95.83	2023-07-17	17.42	轻载	5008.42	5008.42	仓储变/镇江.仓储变/1号主变	20.53	II段母线
扬中	10kV.仓南1C23线	10kV	550	D5000	363.92	2023-08-28	66.17	中载	365.1	365.1	仓储变/镇江.仓储变/1号主变	20.53	II段母线
扬中	10kV.仓储I 1C24线	10kV	550	D5000	116.73	2023-07-31	21.22	轻载	4646.43	4646.43	仓储变/镇江.仓储变/1号主变	20.53	II段母线
扬中	10kV.仓新1C25线	10kV	550	D5000	200.41	2023-08-28	36.44	轻载	3197.09	3197.09	仓储变/镇江.仓储变/1号主变	20.53	II段母线
扬中	10kV.仓镇1C26线	10kV	550	D5000	107.98	2023-07-13	19.63	轻载	4797.98	4797.98	仓储变/镇江.仓储变/1号主变	20.53	II段母线
扬中	10kV.仓北1C31线	10kV	550	D5000	265.5	2023-09-06	48.27	轻载	2069.74	2069.74	仓储变/镇江.仓储变/2号主变	20.31	III段母线
扬中	10kV.通威168线	10kV	550	D5000 INOM	317.52	2023-08-31	57.73	中载	1168.75	1168.75	新坝变/	0	
扬中	10kV.新储170线	10kV	550	D5000	0	2023-09-30	0	轻载	6668.2	6668.2	新坝变/	0	
扬中	10kV.备用231线	10kV	352	D5000	150.32	2023-08-06	42.7	轻载	1664.1	1664.1	扬中变/镇江.扬中变/1号主变	27.32	V段母线
扬中	10kV.雨润152线	10kV	550	D5000	118.76	2023-07-23	21.59	轻载	4611.27	4611.27	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.港北162线	10kV	550	D5000	268.53	2023-07-13	48.82	轻载	2017.26	2017.26	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.年丰164线	10kV	550	D5000	93.93	2023-07-10	17.08	轻载	5041.33	5041.33	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	备用1S26线	10kV	574	D5000	86	2023-08-12	14.98	轻载	5469.65	5469.65	沙港变/镇江.沙港变/2号主变	17.07	III段母线
扬中	10kV.复旦1S35线	10kV	600	D5000	101.4	2023-08-12	16.9	轻载	5518.15	5518.15	沙港变/镇江.沙港变/2号主变	17.07	II段母线
扬中	10kV.城跃166线	10kV	550	D5000	145.68	2023-08-06	26.49	轻载	4145.02	4145.02	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.城扬168线	10kV	600	D5000	80.42	2023-07-14	13.4	轻载	5881.52	5881.52	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.中垠172线	10kV	550	D5000	0	2023-09-30	0	轻载	6668.2	6668.2	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.二墩港174线	10kV	550	D5000	163.83	2023-09-19	29.79	轻载	3830.66	3830.66	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.名都182线	10kV	600	D5000	108.03	2023-07-12	18.01	轻载	5403.32	5403.32	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.锦程153线	10kV	550	D5000	202.81	2023-07-10	36.87	轻载	3155.53	3155.53	城东变/镇江.城东变/2号主变	21.13	II段母线
扬中	10kV.联合1L11线	10kV	550	D5000	105.12	2023-08-31	19.11	轻载	4847.52	4847.52	110kV联合变/镇江.110kV联合	10.4	I段母线
扬中	10kV.联胜1L12线	10kV	550	D5000	63.48	2023-08-07	11.54	轻载	5568.72	5568.72	110kV联合变/镇江.110kV联合	10.4	I段母线
扬中	10kV.红联1L13线	10kV	550	D5000	263.04	2023-08-04	47.83	轻载	2112.34	2112.34	110kV联合变/镇江.110kV联合	10.4	I段母线
扬中	10kV.备用1L14线	10kV	550	D5000	261.24	2023-08-05	47.5	轻载	2143.52	2143.52	110kV联合变/镇江.110kV联合	10.4	I段母线
扬中	10kV.联化1L21线	10kV	550	D5000	105.48	2023-07-10	19.18	轻载	4841.28	4841.28	110kV联合变/镇江.110kV联合	10.4	II段母线
扬中	10kV.联工1L22线	10kV	550	D5000	343.8	2023-08-16	62.51	中载	713.58	713.58	110kV联合变/镇江.110kV联合	10.4	II段母线
扬中	10kV.增配II 1L23线	10kV	550	D5000	170.16	2023-07-13	30.94	轻载	3721.02	3721.02	110kV联合变/镇江.110kV联合	10.4	II段母线
扬中	10kV.联云1L24线	10kV	550	D5000	159	2023-07-12	28.91	轻载	3914.32	3914.32	110kV联合变/镇江.110kV联合	10.4	II段母线
扬中	10kV.备用1L25线	10kV	550	D5000	94.8	2023-08-13	17.24	轻载	5026.26	5026.26	110kV联合变/镇江.110kV联合	10.4	II段母线
扬中	10kV.新生1L31线	10kV	550	D5000	100.4	2023-08-12	18.25	轻载	4929.27	4929.27	110kV联合变/	0	
扬中	10kV.仓跃1C32线	10kV	550	D5000	131.7	2023-07-13	23.95	轻载	4387.15	4387.15	仓储变/镇江.仓储变/2号主变	20.31	III段母线
扬中	10kV.储能1C33线	10kV	550	D5000	0.07	2023-09-27	0.01	轻载	6666.98	6666.98	仓储变/	0	
扬中	10kV.备用1C34线	10kV	550	D5000	359.35	2023-07-20	65.34	中载	444.25	444.25	仓储变/镇江.仓储变/2号主变	20.31	III段母线

扬中	10kV.仓港1C41线	10kV	550	D5000	121.96	2023-08-17	22.17	轻载	4555.85	4555.85	仓储变/镇江.仓储变/2号主变	20.31	IV段母线
扬中	10kV.备用1C42线	10kV	550	D5000	28.41	2023-07-14	5.17	轻载	6176.13	6176.13	仓储变/镇江.仓储变/2号主变	20.31	IV段母线
扬中	10kV.备用1C43线	10kV	550	D5000	292.51	2023-07-14	53.18	中载	1601.92	1601.92	仓储变/镇江.仓储变/2号主变	20.31	IV段母线
扬中	10kV.备用1C44线	10kV	550	D5000	141.92	2023-08-16	25.8	轻载	4210.14	4210.14	仓储变/镇江.仓储变/2号主变	20.31	IV段母线
扬中	10kV.备用1C45线	10kV	465	D5000	159.79	2023-09-28	34.36	轻载	2870.09	2870.09	仓储变/镇江.仓储变/2号主变	20.31	IV段母线
扬中	10kV.西阳184线	10kV	550	D5000	110.21	2023-08-12	20.04	轻载	4759.36	4759.36	西来变/镇江.西来变/2号主变	20.51	IV段母线
扬中	10kV.备用1L32线	10kV	550	D5000	63.24	2023-07-04	11.5	轻载	5572.88	5572.88	110kV联合变/	0	
扬中	10kV.增配 I 1L41线	10kV	550	D5000	128.52	2023-07-31	23.37	轻载	4442.23	4442.23	110kV联合变/	0	
扬中	10kV.备用1L42线	10kV	550	D5000	220.44	2023-07-12	40.08	轻载	2850.17	2850.17	110kV联合变/	0	
扬中	10kV.扬润1Y42线	10kV	550	D5000	139.42	2023-07-01	25.35	轻载	4253.44	4253.44	扬中变/镇江.扬中变/2号主变	20.52	IV段母线
扬中	10kV.备用1Y43线	10kV	352	D5000	109.53	2023-07-12	31.12	轻载	2370.58	2370.58	扬中变/镇江.扬中变/2号主变	20.52	IV段母线
扬中	10kV.备用1Y44线	10kV	352	D5000	224.87	2023-08-13	63.88	中载	372.89	372.89	扬中变/镇江.扬中变/2号主变	20.52	IV段母线
扬中	10kV.备用1Y45线	10kV	352	D5000	18.28	2023-07-12	5.19	轻载	3951.03	3951.03	扬中变/镇江.扬中变/2号主变	20.52	IV段母线
扬中	10kV.人医1Y21线	10kV	480	D5000	152.43	2023-07-12	31.76	轻载	3179.43	3179.43	扬中变/镇江.扬中变/1号主变	27.32	II段母线
扬中	10kV.备用1Y22线	10kV	550	D5000	130.28	2023-08-03	23.69	轻载	4411.75	4411.75	扬中变/镇江.扬中变/1号主变	27.32	II段母线
扬中	10kV.环北1Y23线	10kV	550	D5000	146.46	2023-07-12	26.63	轻载	4131.51	4131.51	扬中变/镇江.扬中变/1号主变	27.32	II段母线
扬中	10kV.备用1Y24线	10kV	400	D5000	71.56	2023-08-12	17.89	轻载	3610.18	3610.18	扬中变/镇江.扬中变/1号主变	27.32	II段母线
扬中	10kV.备用1Y25线	10kV	352	D5000	0	2023-09-30	0	轻载	4267.64	4267.64	扬中变/镇江.扬中变/1号主变	27.32	II段母线
扬中	10kV.备用1Y26线	10kV	352	D5000	2.28	2023-07-11	0.65	轻载	4228.15	4228.15	扬中变/镇江.扬中变/1号主变	27.32	II段母线
扬中	10kV.丰裕1F01线	10kV	485	缺省经验值	251.68	2023-08-08	51.89	中载	1521.04	1521.04	丰裕变/镇江.丰裕变/1号主变	0	I段母线
扬中	10kV.园区1F02线	10kV	485	缺省经验值	265.87	2023-08-16	54.82	中载	1275.27	1275.27	丰裕变/镇江.丰裕变/1号主变	0	I段母线
扬中	10kV.裕西1F13线	10kV	485	缺省经验值	255.09	2023-08-22	52.6	中载	1461.98	1461.98	丰裕变/镇江.丰裕变/2号主变	0	II段母线
扬中	10kV.水厂 II 1F14线	10kV	485	缺省经验值	83.29	2023-07-16	17.17	轻载	4437.55	4437.55	丰裕变/镇江.丰裕变/2号主变	0	II段母线
扬中	10kV.裕工 I 1F20线	10kV	485	缺省经验值	236.46	2023-08-31	48.75	轻载	1784.65	1784.65	丰裕变/镇江.丰裕变/2号主变	0	IV段母线
扬中	10kV.裕东1F19线	10kV	485	缺省经验值	143.83	2023-08-31	29.66	轻载	3389	3389	丰裕变/镇江.丰裕变/2号主变	0	IV段母线
扬中	10kV.裕东1F07线	10kV	485	缺省经验值	282.91	2023-07-06	58.33	中载	980.13	980.13	丰裕变/镇江.丰裕变/1号主变	0	I段母线
扬中	10kV.吾悦 I 1S27线	10kV	485	缺省经验值	188.5	2023-07-16	38.87	轻载	2615.32	2615.32	沙港变/镇江.沙港变/2号主变	17.07	III段母线
扬中	10kV.农商1F03线	10kV	485	缺省经验值	68.08	2023-08-06	14.04	轻载	4700.99	4700.99	丰裕变/镇江.丰裕变/1号主变	0	I段母线
扬中	10kV.裕华1F08线	10kV	485	缺省经验值	130.1	2023-08-06	26.82	轻载	3626.8	3626.8	丰裕变/镇江.丰裕变/1号主变	0	I段母线
扬中	10kV.备用1F15线	10kV	485	缺省经验值	78.29	2023-09-18	16.14	轻载	4524.15	4524.15	丰裕变/镇江.丰裕变/2号主变	0	II段母线
扬中	10kV.备用1F16线	10kV	485	缺省经验值	2.72	2023-07-21	0.56	轻载	5833.02	5833.02	丰裕变/镇江.丰裕变/2号主变	0	II段母线
扬中	10kV.悦峰 I 1C51线	10kV	485	缺省经验值	465.73	2023-07-29	96.03	重载	0	0	仓储变/镇江.仓储变/2号主变	20.31	V段母线
扬中	10kV.悦峰 II 1C52线	10kV	485	缺省经验值	468.95	2023-07-28	96.69	重载	0	0	仓储变/镇江.仓储变/2号主变	20.31	V段母线
扬中	10kV.备用1Y02线	10kV	485	缺省经验值	0	2023-09-30	0	轻载	5880.14	5880.14	油坊变/	0	

扬中	10kV.备用1Y08线	10kV	485	缺省经验值	0	2023-09-30	0	轻载	5880.14	5880.14	油坊变/	0	
扬中	10kV.备用1Y09线	10kV	485	缺省经验值	0	2023-09-30	0	轻载	5880.14	5880.14	油坊变/	0	